

Aqualift F Compact		Accessories	
Illustration and dimensioned drawing	Article description	Outer diameter Ø (mm)	Article #
<p>For models made on or after Jan 2011</p> 	<p><b>Cover plate, surface water tight</b> Class A 15 With drain Ø 75, includes <b>Multistop</b> odour, foam, rodent and insect stop incl. gasket</p> <p><b>1</b> recessed for on-site tiling, grey, for tile thicknesses of 18 mm</p> <p><b>2</b> with integrated grating, black</p> <p>for article numbers: 28 701-C, 28 704-C</p>	-	<b>83 045</b>
		-	<b>83 046</b>
	<p><b>Hair filter</b> made of polymer for article numbers: 83 045 and 83 046</p>	-	<b>43 700</b>
	<p><b>Cover plate, surface water tight</b> Class A 15 made of polymer, incl. gasket Art. # 173-145</p> <p><b>1</b> black Ventilation always required when in use!</p> <p><b>2</b> recessed for on-site tiling, grey, for tile thicknesses of 18 mm Ventilation always required when in use!</p> <p>for article numbers: 28 701-C, 28 704-C</p>	-	<b>83 050</b>
		-	<b>83 052</b>
	<p><b>Upper section</b> made of polymer, max. extension 180 mm, height adjustable for article numbers: 28 701-C, 28 704-C</p>	-	<b>83 061</b>
	<p><b>Transition section Ø 110 / 75</b> Ø 110 socket / Ø 75 spigot can be used as an upper section, incl. gasket for article numbers: 28 701-C, 28 704-C, 28 711-C, 28 743-C</p>	Ø 75/110	<b>27 602</b>
<p><b>NEW</b></p> 	<p><b>Extension section with centre flange</b> with elastomer sealing sheet made of NK/SBR Ø 800 mm, incl. screws for article numbers: 28 701-C, 28 704-C</p>	-	<b>83 075</b>
	<p><b>Gasket set</b> <b>for installation in waterproof concrete</b> Consisting of: <b>Counter flange</b> made of polymer, incl. screws, <b>elastomer waterproof membrane</b> in NK/SBR Ø 800 mm</p> <p>for article numbers: 28 701-C, 28 704-C</p>	-	<b>83 023</b>
<p>WU Einbau geprüft von MFPA Leipzig UB 5.1/11-452-1</p> 	<p><b>Extension section with flange</b> made of polymer, max. extension 180 mm, incl. gasket For gasket set Art. # 83 023 for article numbers: 28 701-C, 28 704-C</p>	-	<b>83 071</b>
<p>When multiple extension sections are used make sure that access to valve is still possible!</p>			